

Stage I



Yearly

Maintenance Inspections of Vapor Recovery System.

The owner or operator of a gasoline storage tank at a gasoline dispensing facility or a bulk gasoline plant subject to Env-Wm 1404.05 shall perform a yearly maintenance inspection:

- (1) No later than September 30 of each calendar year; and
- (2) At least 10 months between each inspection.

Check when completed

Facility Name:	Insp. Date:				
UST Facility ID Number:					
Name of person conducting inspection:					
	Tk1	Tk2	Tk3	Tk4	Tk5
(1) Perform all items specified in <i>Stage I Monthly Maintenance Inspection</i> .					
(2) With the exception of swivel adaptors, remove all adaptors from their riser pipes, apply gasoline resistant thread sealant to cleaned threads, thread the adaptors back onto the riser pipe, and tighten in accordance with the manufacturer's recommendations					
(3) Replace or permanently plug each drain valve located in each spill bucket.					
(4) Verify that adaptor caps and dust covers are not in contact with overlying access covers					
(5) Measure the distance between the tank bottom and the submerged fill tube end to insure a clearance of at least 6 inches (no more than 12 inches), and if necessary, modify the submerged fill tube.					

The owner or operator shall document each annual maintenance inspection, including all findings and repairs made. Please keep this form with your records.